

# ZERTIFIKAT

---

# CERTIFICATE

**Nr./No. 968/EL 570.00/08**

<b>Prüfgegenstand Product tested</b>	SAFCO Fire Alarm Panel System	<b>Inhaber Licence Holder</b>	SAFCO Engineering S.r.l. Via Caduti del Lavoro 10/A 20096 Pioltello (Milano) Italy
<b>Typbezeichnung Type designation</b>	Addressable Fire Alarm Panel System consisting of <ul style="list-style-type: none"> <li>• CLIB-Module</li> <li>• MVI56 Module</li> <li>• SIL2-certified ControlLogix Modules</li> <li>• Application Program</li> </ul>	<b>Verwendungszweck Intended application</b>	Fire Alarm Panel System
<b>Prüfgrundlagen Codes and standards forming the basis of testing</b>	EN54-2:2007 NFPA72:2007 (Chapter 6)		
<b>Prüfungsergebnis Test results</b>	The System fulfils the requirements of EN 54-2 / NFPA72 (chapter 6), considering the results of the test report-no.: 968/EL 570.00/08 dated 2008-11-07.		
<b>Besondere Bedingungen Specific requirements</b>	For the use of the system the test report mentioned above and the User and Installation Manuals have to be considered.		

Der Prüfbericht-Nr.: 968/EL 570.00/08 vom 07.11.2008 ist Bestandteil dieses Zertifikates.

Dieses Zertifikat ist nur gültig für Erzeugnisse, die mit dem Prüfgegenstand übereinstimmen. Es wird ungültig bei jeglicher Änderung der Prüfgrundlagen für den angegebenen Verwendungszweck.

The test report-no.: 968/EL 570.00/08 dated 2008-11-07 is an integral part of this certificate.

This certificate is valid only for products, which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

**TÜV Rheinland Industrie Service GmbH**  
Geschäftsfeld ASI  
Automation, Software und Informationstechnologie  
Am Grauen Stein, 51105 Köln  
Postfach 91 09 51, 51101 Köln



2008-11-07

Datum/Date

Firmenstempel/Company seal

Dipl.-Ing. Stephan Häb